

Motor Protection Module

The service replacement compressor that you have purchased is shipped with two electronic motor protection modules. A 24-volt module is installed in the compressor terminal box and is ready for field control circuit wiring if your control circuit is 24 volts. If the system has a 120-240 volt control circuit, the 24-volt module that is shipped in the compressor terminal box must be removed and the 120-240 volt electronic module that is shipped in the compressor-shipping box must be installed in the compressor terminal box.

Control Voltage	Emerson Part Number
24	071-0607-01
	071-0615-01
	071-0649-01
120-240	071-0607-00
	071-0615-00
	071-0649-00

To remove the motor protection module from the terminal box remove the wires from the S1 and S2 module connections. Gently push and hold down on the tab holding the lower left hand corner of the module to remove the module from the terminal box. To install the correct module simply push it into place behind the plastic stops. Reconnect the sensor circuit wires to S1 and S2. The extra module cannot be returned for credit.

COPELAND

Climate.Emerson.com

2005ECT-126 R4 (2/20) Emerson and Copeland are trademarks of Emerson Electric Co. or one of its affiliated companies. ©2020 Emerson Climate Technologies, Inc. All rights reserved.


EMERSON